



THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column are being used.

GET THE MOST OUT OF YOUR HOSE MONSTER™ HARDWARE

FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT [HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM	PSI	GPM
10	1074	41	2175
11	1126	42	2201
12	1177	43	2227
13	1225	44	2253
14	1271	45	2278
15	1315	46	2304
16	1359	47	2329
17	1400	48	2353
18	1441	49	2378
19	1481	50	2402
20	1519	51	2426
21	1556	52	2449
22	1593	53	2473
23	1629	54	2496
24	1664	55	2519
25	1698	56	2542
26	1732	57	2564
27	1765	58	2587
28	1797	59	2609
29	1829	60	2631
30	1860	61	2653
31	1891	62	2674
32	1921	63	2696
33	1951	64	2717
34	1980	65	2738
35	2009	66	2759
36	2038	67	2780
37	2066	68	2801
38	2094	69	2821
39	2121	70	2842
40	2148		

MANUFACTURED BY THE HOSE MONSTER™ COMPANY