



THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column are being used.

GET THE MOST OUT OF YOUR HOSE MONSTER™ HARDWARE

FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT
[HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM	PSI	GPM
10	1047	41	2120
11	1098	42	2146
12	1147	43	2171
13	1194	44	2196
14	1239	45	2221
15	1282	46	2245
16	1324	47	2270
17	1365	48	2294
18	1405	49	2317
19	1443	50	2341
20	1481	51	2364
21	1517	52	2387
22	1553	53	2410
23	1588	54	2433
24	1622	55	2455
25	1655	56	2478
26	1688	57	2500
27	1720	58	2521
28	1752	59	2543
29	1783	60	2564
30	1813	61	2586
31	1843	62	2607
32	1873	63	2628
33	1902	64	2649
34	1930	65	2669
35	1959	66	2690
36	1986	67	2710
37	2014	68	2730
38	2041	69	2750
39	2068	70	2770
40	2094		

MANUFACTURED BY THE
HOSE MONSTER™ COMPANY