



#### THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column are being used.

#### GET THE MOST OUT OF YOUR HOSE MONSTER™ HARDWARE

#### FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

#### LEARN MORE AT HOSEMONSTER.COM/RESOURCES

PSI	LPM
10	3963
11	4156
12	4341
13	4518
14	4689
15	4853
16	5012
17	5167
18	5316
19	5462
20	5604
21	5742
22	5878
23	6010
24	6139
25	6265
26	6390
27	6511
28	6631
29	6748
30	6864
31	6977
32	7089
33	7199
34	7307
35	7413
36	7519
37	7622
38	7725
39	7826
40	7925

PSI	LPM
41	8024
42	8121
43	8217
44	8312
45	8406
46	8499
47	8591
48	8682
49	8772
50	8861
51	8949
52	9036
53	9123
54	9208
55	9293
56	9377
57	9461
58	9543
59	9625
60	9706
61	9787
62	9867
63	9946
64	10025
65	10103
66	10180
67	10257
68	10333
69	10409
70	10484

MANUFACTURED BY THE  
HOSE MONSTER™ COMPANY