



THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy.

The readings on this chart are based on the differential pressure between the Pitotless Nozzle and Differential Chamber on the In-Line Pitotless Nozzle.

It is the user's responsibility to verify that the correct flow chart is being used. The In-Line Pitotless Nozzle requires a Differential Gauge with a 0.5% accuracy rating or better.

GET THE MOST OUT OF YOUR HOSE MONSTER™ HARDWARE

FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT
[HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM
2	45
3	55
4	63
5	71
6	78
7	84
8	90
9	95
10	100
11	105
12	110
13	114
14	119
15	123
16	127
17	131
18	134
19	138
20	142
21	145
22	149
23	152
24	155
25	159
26	162
27	165
28	168
29	171
30	174
31	176
32	179

PSI	GPM
33	182
34	185
35	188
36	190
37	193
38	195
39	198
40	200
41	203
42	205
43	208
44	210
45	213
46	215
47	217
48	220
49	222
50	224
51	226
52	229
53	231
54	233
55	235
56	237
57	239
58	241
59	243
60	246
61	248
62	250
63	252

PSI	GPM
64	254
65	256
66	258
67	259
68	261
69	263
70	265
71	267
72	269
73	271
74	273
75	275
76	276
77	278
78	280
79	282
80	284
81	285
82	287
83	289
84	291
85	292
86	294
87	296
88	297
89	299
90	301

MANUFACTURED BY
THE HOSE MONSTER™
COMPANY