



#### THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column is being used.

#### GET THE MOST OUT OF YOUR HOSE MONSTER® HARDWARE

#### FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

#### LEARN MORE AT [HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM
10	1074
11	1126
12	1177
13	1225
14	1271
15	1315
16	1359
17	1400
18	1441
19	1481
20	1519
21	1556
22	1593
23	1629
24	1664
25	1698
26	1732
27	1765
28	1797
29	1829
30	1860
31	1891
32	1921
33	1951
34	1980
35	2009
36	2038
37	2066
38	2094
39	2121
40	2148

PSI	GPM
41	2175
42	2201
43	2227
44	2253
45	2278
46	2304
47	2329
48	2353
49	2378
50	2402
51	2426
52	2449
53	2473
54	2496
55	2519
56	2542
57	2564
58	2587
59	2609
60	2631
61	2653
62	2674
63	2696
64	2717
65	2738
66	2759
67	2780
68	2801
69	2821
70	2842