



THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column is being used.

GET THE MOST OUT OF YOUR HOSE MONSTER® HARDWARE

FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT [HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM
10	1047
11	1098
12	1147
13	1194
14	1239
15	1282
16	1324
17	1365
18	1405
19	1443
20	1481
21	1517
22	1553
23	1588
24	1622
25	1655
26	1688
27	1720
28	1752
29	1783
30	1813
31	1843
32	1873
33	1902
34	1930
35	1959
36	1986
37	2014
38	2041
39	2068
40	2094

PSI	GPM
41	2120
42	2146
43	2171
44	2196
45	2221
46	2245
47	2270
48	2294
49	2317
50	2341
51	2364
52	2387
53	2410
54	2433
55	2455
56	2478
57	2500
58	2521
59	2543
60	2564
61	2586
62	2607
63	2628
64	2649
65	2669
66	2690
67	2710
68	2730
69	2750
70	2770