



#### THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column is being used.

#### GET THE MOST OUT OF YOUR HOSE MONSTER® HARDWARE

#### FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT  
[HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	GPM
5	856
6	938
7	1013
8	1083
9	1149
10	1211
11	1270
12	1303
13	1356
14	1407
15	1456
16	1504
17	1550
18	1595
19	1639
20	1682
21	1723
22	1764
23	1803
24	1842
25	1880
26	1917
27	1954
28	1990
29	2025
30	2059

PSI	GPM
31	2093
32	2127
33	2160
34	2192
35	2224
36	2256
37	2287
38	2318
39	2323
40	2353
41	2382
42	2411
43	2439
44	2468
45	2495
46	2523
47	2550
48	2577
49	2604
50	2630
51	2657
52	2683
53	2708
54	2734
55	2759