



#### THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column is being used.

#### GET THE MOST OUT OF YOUR HOSE MONSTER® HARDWARE

#### FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT  
[HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

PSI	LPM
5	3241
6	3550
7	3834
8	4099
9	4348
10	4583
11	4807
12	4930
13	5131
14	5325
15	5512
16	5693
17	5868
18	6038
19	6203
20	6365
21	6522
22	6675
23	6825
24	6972
25	7116
26	7257
27	7395
28	7531
29	7664
30	7795

PSI	LPM
31	7924
32	8051
33	8175
34	8298
35	8420
36	8539
37	8657
38	8773
39	8793
40	8905
41	9016
42	9125
43	9233
44	9340
45	9445
46	9550
47	9653
48	9755
49	9856
50	9956
51	10055
52	10153
53	10251
54	10347
55	10442