



THIS DEVICE IS FM APPROVED

The pressure vs. flow rate data developed within this flow chart is based on the average K-factor measured during laboratory testing. This data has been determined to be within the acceptable limitations for accuracy. It is the user's responsibility to verify that the correct chart and column is being used.

HM2H | 2 1/2" Hose Monster® Model II or Flusher with flow splitter (HM2H, HM2HF)
Use this column if the Pitotless Nozzle® is connected to the 2 1/2" Hose Monster® or Flusher. The built-in pitot or flow splitter must be installed for accuracy.

OA | Open Atmosphere - Use this column when the Pitotless Nozzle® is connected directly to a test header or hydrant flowing openly to atmosphere.

GET THE MOST OUT OF YOUR HOSE MONSTER® HARDWARE

FIRE PUMP TESTING SOFTWARE

Professional-grade software that helps you work better! Keep your reports clean, your results accurate, and your process streamlined with Hose Monster's FPT Software.

LEARN MORE AT [HOSEMONSTER.COM/RESOURCES](https://www.hosemonster.com/resources)

1 3/4" PITOTLESS NOZZLE®

PN1.75THD - GPM FLOW CHART

FC-PN175THD.2023.04.30.MA

	HM2H	OA
PSI	GPM	GPM
5.2*		250
5.7*	250	
10	337	347
11	354	364
12	369	380
13	384	396
14	399	410
15	413	425
16	426	439
17	440	452
18	452	465
19	465	478
20	477	491
21	489	503
22	500	515
23	511	526
24	522	537
25	533	549
26	544	559
27	554	570
28	564	580
29	574	591
30	584	601
31	594	611
32	603	621
33	612	630
34	622	640
35	631	649

	HM2H	OA
PSI	GPM	GPM
36	640	658
37	648	667
38	657	676
39	666	685
40	674	694
41	683	702
42	691	711
43	699	719
44	707	728
45	715	736
46	723	744
47	731	752
48	739	760
49	746	768
50	754	776
51	761	783
52	769	791
53	776	799
54	783	806
55	791	814
56	798	821
57	805	828
58	812	835
59	819	843
60	826	850
61	833	857
62	839	864
63	846	871

	HM2H	OA
PSI	GPM	GPM
64	853	878
65	859	884
66	866	891
67	873	898
68	879	905
69	885	911
70	892	918
71	898	924
72	905	931
73	911	937
74	917	944
75	923	950
76	929	956
77	935	963
78	941	969
79	947	975
80	953	981

* Special flow rate point determined to be within the acceptable limitations of accuracy.

PITOTLESS NOZZLE®

THREADED INSTRUCTIONS

The Pitotless Nozzle® Threaded (PN#THD) must be used in conjunction with the 2 ½" Hose Monster® Model II (HM2H, HM2HF) or attached directly to a hydrant or test header valve discharging into open atmosphere.

Note: If you intend to use the Pitotless Nozzle® with the Little Hose Monster™ (HML), then a Pitotless Nozzle® Grooved (PN#GRV) is required. Do not use the Pitotless Nozzle® Threaded (PN#THD) with the Little Hose Monster™. Call us if you are considering a configuration not listed here.

PITOTLESS NOZZLE® SETUP

The gauge connection on the Pitotless Nozzle® is a factory-installed male end of a quick disconnect coupling. One female counterpart is included and additional ones can be purchased separately. Attach the female end of the quick-disconnect coupling directly to the gauge or remote reader adapter and use the quick-disconnect feature to attach and remove. Do not remove the male quick disconnect from the Pitotless Nozzle® as it will damage the threads on the Pitotless Nozzle®.

We recommend a gauge with an accuracy rating of ½% or better and of a suitable range.

PITOTLESS NOZZLE® USE


WITH THE MODEL II, 2½" HOSE MONSTER® OR FLUSHER

Insert the male outlet of the Pitotless Nozzle® into the swivel coupling of the Hose Monster®. Hand-tighten plus about a quarter-turn using a rocker lug spanner wrench on the swivel coupling and a pin lug spanner wrench (WSPA104) for a holdback on the Pitotless Nozzle®.

Attach the male end of a hose into the swivel coupling on the Pitotless Nozzle®. Hand-tighten plus about a quarter-turn using spanner wrenches. The pitot/flow splitter must remain on either unit in order to collect accurate flow rates. Make sure the hose lies flat and is not twisted.

ON A HYDRANT OR TEST HEADER VALVE

The Pitotless Nozzle® must be attached securely to a pump test header valve or hydrant. Secure the female swivel coupling of the Pitotless Nozzle® directly to a hydrant nozzle or test header valve. The Pitotless Nozzle® points in the direction the water will flow. Clear water discharge path.



WARNING

- **Do not** attach the Pitotless Nozzle® to the end of a hose unless the Hose Monster® is attached or it is **permanently** secured.
- **Do not** attach a hose to the male outlet end of the Pitotless Nozzle® **under any circumstance**. The backpressure will distort flow rate reading.
- **Do not** remove the gauge port quick disconnect fitting. The aluminum threads **will be damaged**. Contact Hose Monster® for any repairs.

LHM			OA		
PSI	GPM	GPM	PSI	GPM	GPM
10	533	282	41	1080	570
11	559	295	42	1093	577
12	584	308	43	1106	584
13	608	321	44	1119	591
14	631	333	45	1131	597
15	653	345	46	1144	604
16	675	356	47	1156	610
17	695	367	48	1169	617
18	716	378	49	1181	623
19	735	388	50	1193	630
20	754	398	51	1205	636
21	773	408	52	1216	642
22	791	418	53	1228	648
23	809	427	54	1239	654
24	826	436	55	1251	660
25	843	445	56	1262	666

FLOW CHARTS

Pitotless Nozzle® flow charts must be used to determine discharge flow rate. The use of flow charts of a different device or size will result in incorrect readings. Within the flow chart is a column for "Little Hose Monster™" and for "Open Atmosphere". Use the "Little Hose Monster™" flows if the Pitotless Nozzle® is attached to a Little Hose Monster™. Use the "Open Atmosphere" flows if the Pitotless Nozzle® is attached directly on a hydrant or test header valve discharging out into the open.

Flow charts are provided with the Pitotless Nozzle® and additional copies are available on our website at www.hosemonster.com



Find this as well as other product guides at: www.hosemonster.com/resources